

RURAL WATER SUPPLY INTERNAL WATER QUALITY MONITORING DISTRICT LABORATORY REPORT ON CHEMICAL ANALYSIS OF WATER (DRINKING) IN RWS&S DIVISION KADAPA																							
Lab Ref No	Mandal	Gramapanchayat	Village Name	Location	Source code	Date of collection & Receipt	Type of Source	Turbidity	PH	Chemical & Toxic substances results expressed in mg/litre													
										Electrical conductivity	Alkalinity	Total Hardness	Calcium Hardness	Magnesium	Total Solids	Chloride	Fluoride	Nitrate	Sulphate	Iron	Date of Analysis	Remarks	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
								2.5	6.50	1000			200	75	30	500	200	0.6	20	200	0.1		
								10	9.2	3000		600	600	200	100	2000	1000	1.5	45	400	0.3		
1829/16	Mylavaram	Mylavaram	Mylavaram	To water sample collect Ultra Mega Solor Park at Mylavaram mandal		25.06.16	BW		6.95	546	232	176	80	23	349	136	0.29	2.5	24	0.03	25.06.16	Potable	

D.Rama Chandrudu
Chemist/RWS/KAP.

Disclaimer: This information is only general assessment provided as a general guidance to the bidders. Bidders who require accurate data have to make their own assessment / investigation. APSPCL takes no responsibility for the above data or variation in the data what so ever.