



- NOTES:**
1. ALL DIMENSIONS ARE IN MILLIMETERS.
 2. DO NOT SCALE THE DRAWING. ONLY FIGURED DIMENSIONS SHALL BE FOLLOWED.
 3. GRID LINES ARE DRAWN AT 2000M X 2000M INTERVAL.
 4. WATER TAPPING POINT SHALL BE PROVIDED AT ONE POINT PER PLOT. INDIVIDUAL DEVELOPERS SHALL MAKE NECESSARY ARRANGEMENTS FOR STORAGE & DISTRIBUTION WITHIN THE PLOT.
 5. SOLAR POWER DEVELOPERS SHALL NOT DISTURB THE NATURAL STREAMS AND WATER BODIES FLOWING THROUGH THE PLOTS.
 6. 35M WIDE CORRIDOR PROVIDED FOR 220 KV TRANSMISSION LINE.
 7. 45M WIDE CORRIDOR PROVIDED FOR 400 KV TRANSMISSION LINE.

LEGEND PLOT ALLOCATION

	P1 TO P5	BLOCK - 1
	P6 TO P10	BLOCK - 2
	P11 TO P15	BLOCK - 3

LEGEND

	PROJECT BOU.		WELL
	GOVT. LAND		BUND
			CHECK DAM
			SETTLEMENT
	CART TRACK		SPOIL BANK
	400 KV CORRIDOR		STONE
	200 KV CORRIDOR		TEMPLE
			WATER TANK
	POOLING STATION		UTILITY CORRIDOR
	TRANSMISSION CUM UTILITY		APSPCL LAND
	CONNECTING ROAD		CANAL
	VILLAGE BOUNDARY		STREAM

ANDHRA PRADESH SOLAR POWER CORPORATION LIMITED

PROJECT TITLE
KADAPA ULTRA MEGA SOLAR PARK
PHASE -II (750 MW)

DRAWING TITLE
PLOT PLAN

SCALE : CONTEC DESIGN & ENGINEERING SOLUTIONS PVT. LTD.

REVISION DETAILS					CATEGORY OF DRAWING				
NO.	INIT.	DATE	DESCRIPTION	APPROVED	DATE	SPECIFICATION	APPROVAL	REFERENCE	CONSTRUCTION
1	DR	22.01.2018	400 KV SUB STATION SHIFTED TO NEW LOCATION AS PER APTRANSCO ADVISE				BY	DATE	INITIAL
2	DR	13.04.2018	PLOT BOUNDARIES OF P13,P14 AND P15 ARE CHANGED.			DRAWN		30 JAN 2018	SH
						CHECKED	DR	30 JAN 2018	DR
						APPROVED		30 JAN 2018	RRH
						DRAWING NO.	SHEET NO.	REVISION	DATE
						CT/CUMSP/PP/001	1	R2	13 April 2018

© ConTec Design & Engineering Solutions Pvt. Ltd.